Kane Constructions Pty Ltd



Parramatta NRL Centre of Excellence & Community Facility

Dust Monitoring Graphs Site Compound 01 Sep 2024 - 30 Sep 2024 pg/m³ 1d averages 65 40 00 Sep 04 Sep 06 Sep 08 Sep 10 Sep 12 Sep 14 Sep 16 Sep 18 Sep 20 Sep 22 Sep 24 Sep 26 Sep 28 Sep 30 Sep Parameters — PM10 Thresholds

	_			
Dai	L,	NI	\sim	-
Dui	IV	IN	O	125

---- 50 Dust PM10

Date and time	Ву	Note
01 Oct 2024 11:08	Michael	Extreme wind conditions 18th and 19th September contributing to dust exceedance.

Device Details

Device Serial	Monitoring Points	Model	Calibration Date	Calibration Due
HEX-000390	Site Compound	SiteHive Hexanode	29 Aug 2023	29 Aug 2025